

CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

Magnetawan Municipality
Fire Department

F.S. #1 Magnetawan (7)
F.S #2 Ahmic Harbour (7)

Date Test Passed: September 6, 2023

Residential and Industrial Certification (7)

Flow Achieved: 420 I.G.P.M Liters Per Min: 1911
Two (2) Hour Test Time

Signed: Melissa Rose
Melissa Rose – Principal

This Certificate is valid for 5 years and expires September 7, 2028